

ENGINEERING DEPARTMENT  
*Town of Poughkeepsie*

**PETER D. SETARO, P. E.**  
Town Engineer

ONE OVEROCKER ROAD  
POUGHKEEPSIE, NY 12603

**DONALD A. BEER**  
Associate Town Engineer

TEL # (845) 790-4736

**SEAN CRIMMINS**  
Assistant Town Engineer

TEL # (845) 790-4767

**MEMORANDUM**

**2/14/12**

**To:**           **Portable Water Pump Bidders**  
**From:**       Sean Crimmins, Assistant Town Engineer  
**Subject:**     Addendum No. 1

=====

Following are clarifications and answers to questions received for the Portable Water Pump bid due to open on February 24, 2012:

1. The transfer hose as specified under the required items within the Technical Specifications shall be Heavy Duty with a rating of one hundred and fifty (150) psi.
2. A question was asked if the "Guarded Control Panel" under the additional features within the Technical Specifications was to include anti-tampering features. Anti-tampering features are not required. This panel shall be computerized to allow control for all pertinent operations of the pump equipment.

SC/cb