

ENGINEERING DEPARTMENT  
*Town of Poughkeepsie*

**PETER D. SETARO, P. E.**  
Town Engineer

**ONE OVEROCKER ROAD**  
**POUGHKEEPSIE, NY 12603**

**DONALD A. BEER**  
Associate Town Engineer

**TEL # (845) 790-4736**

**SEAN CRIMMINS**  
Assistant Town Engineer

**TEL # (845) 790-4767**

**MEMORANDUM**

**2/16/12**

**To:**           **Route 9G Pump Station Bidders**

**From:**       Sean Crimmins, Assistant Town Engineer

**Subject:**     Addendum No. 1

=====

Following are clarifications and answers to questions received for the Route 9G Pump Station bid due to open on February 24, 2012:

1. The required performance under the Technical Specifications has changed to “Two (2) pumps capable of delivering 205 GPM at 21’ TDH with a maximum static suction lift of 17 FT. 3 phase, 60 cycle 230 Volt motor driven. Pump station assembly must be capable of mounting to an existing 5’-0” diameter wet well.”

SC/cb